

Workshop with TAG

Wastewater Strategy Study



Rotorua WWTP

28 May 2015

Kevan Brian



Scope of Works

- ❑ Identify the most appropriate treatment process for the WWTP to meet future nutrient limits of 30tN/yr and 3tP/yr.
- ❑ Study based on identifying a treatment process that will meet the proposed nutrient limits without any assumption of using TERAX or not
- ❑ Compare to other processes/ plant to validate likely performance
- ❑ CAPEX, OPEX and NPV



Project Drivers

- ❑ Ability to meet the mass discharge of 30tN/yr and 3tP/yr from the plant.
- ❑ Requires an average total N of 3.5mg/L in future (4.1mgN/L now)
- ❑ Requires an average total P of 0.35mgP/L in future (0.4mgP/L now)
- ❑ No clear bio solids drivers – max dry solids and minimum volume assumed
- ❑ No disinfection standard but a likely requirement if final effluent is discharged to surface water



Current treated Wastewater Quality (29/5/12 to 21/5/15)

Bardenpho

Parameter	Units	Mean	Median
COD	mg/L	44	38
Suspended Solids	mg/L	23	19
Total Phosphorus	mgP/L	3.42	3.21
DRP	mgP/L	2.48	2.48
Total Nitrogen	mgN/L	6.18	5.13
Total K Nitrogen	mgN/L	2.61	2.24
Ammonia Nitrogen	mgN/L	0.33	0.08
Nitrate	mgN/L	2.04	1.57

MBR

Parameter	Units	Mean	Median
COD	mg/L	17	16
Suspended Solids	mg/L	<1	<1
DRP	mgP/L	1.43	1.2
Total Nitrogen	mgN/L	3.91	3.14
Total K Nitrogen	mgN/L	1.34	1.06
Ammonia Nitrogen	mgN/L	1.24	0.13
Nitrate	mgN/L	2.43	1.64



Option Selection – Phosphorus Removal

- ❑ Good nitrogen removal and biological phosphorus removal can be achieved in current plant(s)
- ❑ Both N & P removal has not been consistently achieved at same time
- ❑ N&P removal compete for carbon: need COD:N ratio of >15 in influent (currently 11:1)
- ❑ Could dose more carbon to remove P or dose Alum
- ❑ Additional Carbon (acetic acid) is double the cost of Alum

Conclusion use chemicals to remove phosphorus



Option Selection – Filtration

- ❑ Bardenpho has high suspended solids in effluent (ave 23mg/L)
- ❑ These solids contain N & P – about 7%N and 2%P
- ❑ If current performance is maintained then effluent TSS represents 10tN/yr and 3.65tP/yr
- ❑ Removing solids is essential if targets are to be met
- ❑ Best filtration (most solids removed) is via membrane filtration – UF or similar

Conclusion filtration of final is essential to meet future limits – membranes will give highest TSS removal (smallest effective pore size)



Option Selection – Nitrogen Removal

- ❑ Many ways to remove nitrogen including current type of process
- ❑ Nitrogen removal efficiency of approx 93% needed to meet new limits
- ❑ Can a single stage process achieve this or is a tertiary system needed
 - ❑ Tertiary system has better efficiency as this uses a multiplier effect
- ❑ Can the required level of N removal be achieved without tertiary treatment (other than filtration)?



Option Selection – Nitrogen Removal

- ❑ Water Research Foundation (WERF) study “Quantifying Nutrient Removal Technology Performance”
- ❑ Takes 22 of the best performing plants in US and compares N&P removal against, plant type and configuration



Option Selection – Nitrogen Removal

Plant	Configuration	Median TN (mg/L)	N Removal
Piscataway, MD (78,000m ³ /d)	Activated sludge and Tertiary Filters	3.00	86%
Eastern WRF, FL (64,000m ³ /d)	Bardenpho and tertiary Filters	3.64	90%
Parkway, MD (21,600m ³ /d)	4 Stage Bardenpho	3.40	88%
Rotorua WWTP (23,800m ³ /d)	?	3.50	93%



Option Selection – Nitrogen Removal

- ❑ Single Stage Process can meet limits proposed, however:
 - ❑ Data presented by WERF is based on median (or 50% of the time) performance
 - ❑ If higher levels of confidence are required say 90th percentile (i.e 90% of samples are less than) then tertiary process essential
 - ❑ Important for setting limits of consent – median/mean concentration and average flow
- ❑ Single stage process considered suitable for limits proposed (i.e. ave or median of 3.5mgN/L)



Option Selection – Carbon Balance

- ❑ Availability of COD essential to getting low N
- ❑ Current plant removes 40% of COD in primary and removes this from site (via dewatering)
- ❑ TERAX concept is to use this sludge to produce vfa and reduce ethanol consumption
- ❑ Why remove all this COD and “waste” its value?
- ❑ Option to bypass primary treatment and make most use of COD in wastewater – this reduces ethanol and reduces sludge production overall



Option Selection – Carbon Balance

- ❑ Potential to reduce ethanol use by 700L/d
- ❑ Reduce sludge production by 40%
- ❑ Consequence is that there are more solids in secondary reactor (Bardenpho)
- ❑ Unlikely that clarifiers will have sufficient capacity to handle increased flow and increased solids.
- ❑ Could add more clarifiers
- ❑ Consider alternatives?



Process Selection

- ❑ Given that:
 - ❑ Phosphorus removal is via chemical means
 - ❑ Filtration is essential
 - ❑ Single stage process can achieve standards
 - ❑ Can make better use of carbon but this would mean clarifiers of Bardenpho over loaded
 - ❑ Disinfection likely to be required




Process Selection

- ❑ Ideal Process is:
 - ❑ Bypass of primary tanks
 - ❑ Conversion of Bardenpho reactor to MBR and modify aeration
 - ❑ Dewater Biosolids and remove from site either as a "cake" or destroy solids via TERAX
- ❑ Costs prepared on basis of building a new membrane tank, as may be very difficult to convert clarifiers and keep plant live
- ❑ Standards for disinfection unknown but UF will remove bacteria



Process Selection

- Performance of MBR (current) with respect to indicator organisms:
 - Median FC – 0FC/100mL
 - 95th % ile FC – 14FC/100mL
 - Median E. coli – 0/100mL
 - 95th % ile – 6/100mL
- Virus removal not known but likely to be in the order of 4-5 log removal over process (i.e 99.99% to 99.999%)



Process Selection

- ❑ Membranes – assumed GE ZeeWeed (as per existing)
 - ❑ 40 Cassettes (currently there are 8) in four “trains” of 10
 - ❑ Peak flow (Bardenpho only) – 805L/s – all trains or 604L/s with one train out
 - ❑ Peak flow Bardenpho and Side stream MBR – 935L/s or 735L/s with one train out



Costs

- ❑ CAPEX - \$21.15 Million inclusive of dewatering and alum dosing
- ❑ CAPEX with contingency and non works costs - \$31 Million
- ❑ Note that non works costs are based on same rates as other studies and are indicative only
- ❑ Scope for significant savings if clarifiers could be converted
- ❑ OPEX \$2.96 Mill/yr or \$0.4/m³ treated
 - ❑ Includes membrane air, replacement membranes, alum, polymer (dewatering) , sludge disposal (\$130/tonne), electricity and maintenance and alum dosing

